

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR**

SUMMERSVILLE MUNICIPAL WATER, WV3303404

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 8/1/2024 and 8/31/2024, we failed to submit the required samples as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

| Required Monitoring | Compliance Period |
|---|-----------------------|
| 27, MONITORING, ROUTINE (DBP), MAJOR Failure to Report Required Chlorine Residual With a Coliform Sample Result | 8/1/2024 to 8/31/2024 |

What happened? What is being done? (Describe corrective action)

CHLORINE RESIDUAL WAS TAKEN DURING SAMPLE COLLECTION WITH A RESULT
OF 1.9 PPM. THE RESULT WAS NOT ENTERED ON SAMPLE BY MISTAKE.
FUTURE SAMPLES TAKEN HAVE CHLORINE RESIDUAL REPORTED.

For more information, please contact ROBERT BROWN at 304-872-3347
(Contact name) (Phone number)
or P.O. BOX 525, SUMMERSVILLE WV 26651
(Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **SUMMERSVILLE MUNICIPAL WATER**

State Water System ID #: WV3303404

Date Distributed: 9/1/25